

# A Cross Breed Multilevel D-Statcom-Control Conspire For Control Quality Change

### <sup>#</sup>K.SADANANDAM, Associate Professor & HOD,

Department of EEE,

MOTHER THERESSA COLLEGE OF ENGINEERING & TECHNOLOGY, PEDDAPALLI, TS, INDIA.

*Abstract:* A Power quality problem is an occurrence manifested as a nonstandard voltage, current or frequency that results in a failure or a mis operation of end user equipments. Utility distribution networks, sensitive industrial loads and critical commercial operations suffer from various types of outages and service interruptions which can cost significant financial losses. With the restructuring of power systems and with shifting trend towards distributed and dispersed generation, the issue of power quality is going to take newer dimensions. Injection of the wind power into an electric grid affects the power quality. The influence of the wind turbine in the grid system concerning the power quality measurements are-the active power, reactive power, variation of voltage, flicker, harmonics, and electrical behavior of switching operation and these are measured according to national/international guidelines specified in International Electro-technical Commission standard, IEC-61400. The paper study demonstrates the power quality problem due to installation of wind turbine with the grid. In this proposed scheme distribution static compensator (DSTATCOM) is connected with a battery energy storage system (BESS) to mitigate the power quality issues. The battery energy storage is integrated to sustain the real power source under fluctuating wind power. The DSTATCOM control scheme for the grid connected wind energy generation system for power quality improvement is simulated using MATLAB/SIMULINK in power system block set. Finally the proposed scheme is applied for both balanced and unbalanced nonlinear loads.

Keywords: DSTATCOM, power quality, wind generating system (WGS).

#### I. INTRODUCTION

One of the most common power quality problems today is voltage dips. A voltage dip is a short time (10 ms to 1 minute) event during which a reduction in r.m.s voltage magnitude occurs. It is often set only by two parameters, depth/magnitude and duration. The voltage dip magnitude is ranged from 10% to 90% of nominal voltage (which corresponds to 90% to 10% remaining voltage) and with a duration from half a cycle to 1 min. In a three-phase system a voltage dip is by nature a threephase phenomenon, which affects both the phase-to-ground and phase-to-phase voltages. A voltage dip is caused by a fault in the utility system, a fault within the customer"s facility or a large increase of the load current, like starting a motor or transformer energizing. Typical faults are single-phase or multiple-phase short circuits, which leads to high currents. The high current results in a voltage drop over the network impedance. At the fault location the voltage in the faulted phases drops close to zero, whereas in the non-faulted phases it remains more or less unchanged [1, 2]. Voltage dips are one of the most occurring power quality problems. Off course, for an industry an outage is worse, than a voltage dip, but voltage dips occur more often and cause severe problems and economical losses. Utilities often focus on disturbances from end-user equipment as the main power quality problems. This is correct for many disturbances, flicker, harmonics, etc., but voltage dips mainly have their origin in the higher voltage

levels. Faults due to lightning, is one of the most common causes to voltage dips on overhead lines. If the economical losses due to voltage dips are significant, mitigation actions can be profitable for the customer and even in some cases for the utility. Since there is no standard solution which will work for every site, each mitigation action must be carefully planned and evaluated. There are different ways to mitigate voltage dips, swell and interruptions in transmission and distribution systems. At present, a wide range of very flexible controllers, which capitalize on newly available power electronics components, are emerging for custom power applications [3, 4]. Among these, the distribution static compensator and the dynamic voltage restorer are most effective devices, both of them based on the VSC principle. STATCOM is often used in transmission system. When it is used in distribution system, it is called D-STATCOM ( STATCOM in Distribution system). D-STATCOM is a key FACTS controller and it utilizes power electronics to solve many power quality problems commonly faced by distribution systems. Potential applications of D-STATCOM include power factor correction, voltage regulation, load balancing and harmonic reduction. Comparing with the SVC, the D-STATCOM has quicker response time and compact structure. It is expected that the D-STATCOM will replace the roles of SVC in nearly future. D-STATCOM and STATCOM are different in both structure and function, while the choice of



International Journal of Research Available at <u>https://edupediapublications.org/journals</u> <u>Special Issue on Conference Papers</u> e-ISSN: 2348-6848 p-ISSN: 2348-795X Volume 05 Issue 06 March 2018

control strategy is related to the main-circuit structure and main function of compensators [3], so D-STATCOM and STATCOM adopt different control strategy. At present, the use of STATCOM is wide and its strategy is mature, while the introduction of D-STATCOM is seldom reported. Many control techniques are reported such as instantaneous theory, etc. In this paper, an indirect current control technique (Singh et al., 2000a, b) is employed to obtain gating signals for the Insulated Gate Bipolar Transistor (IGBT) devices used in current controlled voltage source inverter (CC-VSI) working as a DSTATCOM. A model of DSTATCOM is developed using MATLAB for investigating the transient analysis of distribution system under balanced/unbalanced linear and nonlinear three-phase and single-phase loads (diode rectifier with R and R-C load). Simulation results during steady-state and transient operating conditions of the DSTATCOM are presented and discussed to demonstrate power factor correction, harmonic elimination and load balancing capabilities of the DSTATCOM system [5-10].

#### **II. WIND ENERGY SYSTEM**

A simplified diagram representing some of the common types of wind energy systems are shown in Fig.2. From the design perspective it is found that some generators are directly connected to the grid through a dedicated transformer while others in corporate power electronics. Many designs, however, include some level of power Electronics to improve controllability and operating range. Whatever connection configuration is used, each turbine itself has an effect on the power quality of the transmission system. Recent analysis and study shows that the impact of the yaw error and horizontal wind shear on the power (torque) and voltage oscillations is more severe than the effects due to the tower shadow and vertical wind shear.



Fig.1 Different types of wind energy system The above figure shows different types of wind energy system. The new grid comes adopted for wind power

integration has identified the problems of integrating large amounts of wind energy to the electric grid. It suggests that new wind farms must be able to provide voltage and reactive power control, frequency control and fault ride-through capability in order to maintain the electric system stability. For the existing wind farms with variable speed, double-fed induction generators (DFIG) and synchronous generators (SG), a frequency response in the turbine control system can be frequency response in the turbine control system can be incorporated by a software upgrade. Wind farms with fixed speed induction generators (FSIG) have to be phased out because they cannot offer the required voltage or frequency control. An overview of the developed controllers for the converter of grid connected system and showed that the DFIG has now the most efficient design for the regulation of reactive power and the adjustment of angular velocity to maximize the output power efficiency. These generators can also support the system during voltage sags. However, the drawbacks of converter-base systems are harmonic distortions injected into the system. Being a single-stage buck-boost inverter, with Zsource inverter can be a good candidate to mitigate the PQ problems for future DG systems connected to the grid Fig(2).



Fig.2 PMSG-base WECS with dc boost chopper and ZSI

Anti- islanding is one of the important issues for grid connected DG system. A major challenge for the islanding operation and control schems is the protection coordination of distribution systems with bidirectional flows of fault current. This is unlike the conventional over-current protection for radial systems with unidirectional flow of fault current. Therefore extensive research in being carried out and an overview of the existing protection techniques with islanding operation and control, for preventing disconnection of DGs during loss of grid, has been discussed.



# III.DISTRIBUTION STATIC COMPENSATOR (D-STATCOM)

#### 3.1 Principle of DSTATCOM

A D-STATCOM (Distribution Static Compensator), which is schematically depicted in Fig.1, consists of a two-level Voltage Source Converter (VSC), a dc energy storage device, a coupling transformer connected in shunt to the distribution network through a coupling transformer. The VSC converts the dc voltage across the storage device into a set of threephase ac output voltages. These voltages are in phase and coupled with the ac system through the reactance of the coupling transformer. Suitable adjustment of the phase and magnitude of the D-STATCOM output voltages allows effective control of active and reactive power exchanges between the DSTATCOM and the ac system. Such configuration allows the device to absorb or generate controllable active and reactive power.

The VSC connected in shunt with the ac system provides a multifunctional topology which can be used for up to three quite distinct purposes:

- 1. Voltage regulation and compensation of reactive power;
- 2. Correction of power factor; and
- 3. Elimination of current harmonics.

Here, such device is employed to provide continuous voltage regulation using an indirectly controlled converter.



#### Figure. 3 DSTATCOM

Fig. 1 the shunt injected current Ish corrects the voltage sag by adjusting the voltage drop across the system impedance Zth. The value of Ish can be controlled by adjusting the output voltage of the converter. The shunt injected current Ish can be written as,

Ish = IL - IS = IL - (Vth - VL) / Zth $Ish /_\eta = IL /_- \theta$ 

Ssh = VL Ish\*

The complex power injection of the D-STATCOM can be expressed as,

It may be mentioned that the effectiveness of the DSTATCOM in correcting voltage sag depends on the value of Zth or fault level of the load bus. When the shunt injected current Ish is kept in quadrature with VL, the desired voltage correction can be achieved without injecting any active power into the system. On the other hand, when the value of Ish is minimized, the same voltage correction can be achieved with minimum apparent power injection into the system.

#### 3.2 Voltage Source Converter (VSC)

A voltage-source converter is a power electronic device that connected in shunt or parallel to the system. It can generate a sinusoidal voltage with any required magnitude, frequency and phase angle. The VSC used to either completely replace the voltage or to inject the "missing voltage". The "missing voltage" is the difference between the nominal voltage and the actual. It also converts the DC voltage across storage devices into a set of three phase AC output voltages [8, 9]. In addition, D-STATCOM is also capable to generate or absorbs reactive power. If the output voltage of the VSC is greater than AC bus terminal voltages, D-STATCOM is said to be in capacitive mode. So, it will compensate the reactive power through AC system and regulates missing voltages. These voltages are in phase and coupled with the AC system through the reactance of coupling transformers. Suitable adjustment of the phase and magnitude of the DSTATCOM output voltages allows effectives control of active and reactive power exchanges between D-STATCOM and AC system. In addition, the converter is normally based on some kind of energy storage, which will supply the converter with a DC voltage [10].

#### **3.3 Controller for DSTATCOM**

The three-phase reference source currents are computed using three-phase AC voltages (*v*ta, *v*tb and *v*tc) and DC bus voltage (*V*dc) of DSTATCOM. These reference supply currents consist of two components, one in-phase (*I*spdr) and another in quadrature (*I*spqr) with the supply voltages. The control scheme is represented in Fig. 4. The basic equations of control algorithm of DSTATCOM are as follows.

# **3.3.1** Computation of in-phase components of reference supply current

The instantaneous values of in-phase component of reference supply currents (*Ispdr*) is computed using one PI controller over the average value of DC bus voltage of the DSTATCOM (*vdc*) and reference DC voltage (*vdcr*) as

$$I_{spdx(n)} = I_{spdx_{(n-1)}} + K_{pd} \{ v_{de(n)} - v_{de(n-1)} \} + K_{id} v_{de(n)}$$

Where  $Vde(n) \square \square Vdcc-Vdcn$  denotes the error in Vdcc and average value of Vdc *Kpd* and *Kid* are proportional and integral gains of the DC bus voltage PI controller. The output of this PI controller (*I*spdr) is taken as amplitude of in-phase



component of the reference supply currents. Three-phase inphase components of the reference supply currents (*isadr*, *isbdr* and *iscdr*) are computed using the in-phase unit current vectors (*ua*, *ub* and *uc*) derived from the AC terminal voltages (*vtan*, *vtbn* and *vtcn*), respectively.

$$u_{a} = v_{ta}/V_{tm}, \quad u_{b} = v_{tb}/V_{tm}, \quad u_{c} = v_{tc}/V_{tm}$$

Where Vtm is amplitude of the supply voltage and it is computed as

$$\boldsymbol{V}_{\text{tm}} = \left[ (2/3) \left( v_{\text{tan}}^2 + v_{\text{tin}}^2 + v_{\text{tcn}}^2 \right) \right]^{1/2}$$

The instantaneous values of in-phase component of reference supply currents (*isadr*, *isbdr* and *iscdr*) are computed as

$$I_{\operatorname{spqu}(n)} = I_{\operatorname{spqu}(n-1)} + K_{\operatorname{pq}} \left\{ v_{\operatorname{se}(n)} - v_{\operatorname{se}(n-1)} \right\} + K_{\operatorname{iq}} \, v_{\operatorname{se}(n)}$$

Where Vac= Vtmc-Vmc(n) denotes the error in Vtmc and computed value *Vtmn* from Equation (3) and Kpqand Kiq are the proportional and integral gains of the second PI controller.

$$w_{s} = \left\{-u_{b} + u_{c}\right\} / \left\{(3)^{1/2}\right\}$$
$$w_{b} = \left\{u_{a}(3)^{1/2} + u_{b} - u_{c}\right\} / \left\{2(3)^{1/2}\right\}$$
$$w_{c} = \left\{-u_{a}(3)^{1/2} + u_{b} - u_{c}\right\} / \left\{2(3)^{1/2}\right\}$$

Three-phase quadrature components of the reference supply currents (*i*saqr, *i*sbqr and *i*scqr) are computed using the output of second PI controller (*I*spqr) and quadrature unit current vectors (*w*a, *w*b and *w*c) as



Figure. 4 Control scheme for DTSATCOM connected to grid supply

#### 3.3.3 Computation of total reference supply currents

Three-phase instantaneous reference supply currents (*isar*, *isbr* and *iscr*) are computed by adding in-phase (*isadr*, *isbdr* and *iscdr*) and quadrature components of supply currents (*isaqr*, *isbqr* and *iscqr*) as

$$i_{\rm sac}=i_{\rm sade}+i_{\rm sage},\quad i_{\rm sbe}=~i_{\rm sbde}+~i_{\rm sbge},\quad i_{\rm see}=i_{\rm sede}+i_{\rm sege}$$

A hysteresis pulse width modulated (PWM) current controller is employed over the reference (*isar*, *isbr* and *iscr*) and sensed supply currents (*isa*, *isb* and *isc*) to generate gating pulses for IGBTs of DSTATCOM.

# IV.MATAB/SIMULINK MODELING OF DSTATCOM

#### 4.1Modeling of Power Circuit



Figure. 5. Matlab/Simulink Model of DSTATCOM Fig. 5 shows the complete MATLAB model of DSTATCOM along with control circuit. The power circuit as well as control system are modelled using Power System Blockset and Simulink. The grid source is represented by three-phase AC source. Three-phase AC loads are connected at the load end. DSTATCOM is connected in shunt and it consists of PWM voltage source inverter circuit and a DC capacitor connected at its DC bus. An IGBT-based PWM inverter is implemented using Universal bridge block from Power Electronics subset of PSB. Snubber circuits are connected in parallel with each IGBT for protection. Simulation of DSTATCOM system is carried out for linear and non-linear loads. The linear load on the system is modelled using the block three-phase parallel R-L load connected in delta configuration. The non-linear load on the system is modelled using R and R-C circuits connected at output of the diode rectifier. Provision is made to connect loads in parallel so that the effect of sudden load addition and



Available at <u>https://edupediapublications.org/journals</u> Special Issue on Conference Papers

removal is studied. The feeder connected from the three-phase source to load is modelled using appropriate values of resistive and inductive components.

#### 4.2 Modeling of Control Circuit

Fig. 6 shows the control algorithm of DSTATCOM with two PI controllers. One PI controller regulates the DC link voltage while the second PI controller regulates the terminal voltage at PCC. The in-phase components of DSTATCOM reference currents are responsible for power factor correction of load and the quadrature components of supply reference currents are to regulate the AC system voltage at PCC.



Figure. 6 Control Circuit

The output of PI controller over the DC bus voltage (Ispdr) is considered as the amplitude of the in-phase component of supply reference currents and the output of PI controller over AC terminal voltage (Ispqr) is considered as the amplitude of the quadrature component of supply reference currents. The instantaneous reference currents (isar, isbr and iscr) are obtained by adding the in-phase supply reference currents (isadr, isbdr and iscdr) and quadrature supply reference currents (isaqr, isbqr and iscqr). Once the reference supply currents are generated, a carrierless hysteresis PWM controller is employed over the sensed supply currents (isa, isb and isc) and instantaneous reference currents (isar, isbr and iscr) to generate gating pulses to the IGBTs of DSTATCOM. The controller controls the DSTATCOM currents to maintain supply currents in a band around the desired reference current values. The hysteresis controller generates appropriate switching pulses for six IGBTs of the VSI working as DSTATCOM.

# **V.SIMULATION RESULTS**

Here Simulation results are presented for two cases. In case one load is balanced non linear and in case two unbalanced non linear load is considered.

#### 5.1 Case one

Performance of DSTATCOM connected to a weak supply system is shown in Fig.7.This figure shows variation of performance variables such as supply voltages (vsa, vsb and vsc), terminal voltages at PCC (vta, vtb and vtc), supply currents (*isa*, *isb* and *isc*), load currents (*ila*, *ilb* and *ilc*), DSTATCOM currents (*ica*, *icb* and *icc*) and DC link voltage (Vdc).



Figure. 7 Simulation results for Balanced Non Linear Load Fig. 7 shows the source current, load current, compensator current and induction generator currents plots respectively. Here compensator is turned on at 0.1 seconds.



Figure. 8 Simulation results power factor for Non linear Load Fig. 8 shows the power factor, it is clear from the figure that after compensation power factor is unity.

#### 5.2 Case two

Un Balanced three-phase non-linear load is represented by three-phase uncontrolled diode bridge rectifier with pure resistive load at its DC bus. Fig. 9 shows the transient



responses of distribution system with DSTATCOM for supply voltages (*v*sabc), supply currents (*i*sabc), load currents (*i*la, *i*lb and *i*lc), DSTATCOM currents (*i*ca, *i*cb and *i*cc) along with DC link voltage (*V*dc) and its reference value (*V*dcr) at rectifier nonlinear load.



Figure. 9 Simulation results for Non- Linear Unbalanced Load Fig.9 shows the unbalanced non linear load case. From the figure it is clear that even though load is unbalanced source currents are balanced and sinusoidal.

# VI. CONCLUSION

DSTATCOM system is an efficient mean for mitigation of PQ disturbances introduced to the grid by DERs. DSTATCOM compensator is a flexible device which can operate in current control mode for compensating voltage variation, unbalance and reactive power and in voltage control mode as a voltage stabilizer. The latter feature enables its application for compensation of dips coming from the supplying network. The simulation results show that the performance of DSTATCOM system has been found to be satisfactory for improving the power quality at the consumer premises. DSTATCOM control algorithm is flexible and it has been observed to be capable of correcting power factor to unity, eliminate harmonics in supply currents and provide load balancing. It is also able to regulate voltage at PCC. The control algorithm of DSTATCOM has an inherent property to provide a self-supporting DC bus of DSTATCOM. It has been found that the DSTATCOM system reduces THD in the supply currents for non-linear loads. Rectifier-based nonlinear loads generated harmonics are eliminated by DSTATCOM. When single-phase rectifier loads are connected. DSTATCOM currents balance these unbalanced load currents.

#### REFERENCES

[1] A.E. Hammad, Comparing the Voltage source capability of Present and future Var Compensation Techniques in Transmission System, *IEEE Trans, on Power Delivery*. *Volume 1. No.1* Jan 1995.

[2] G.Yalienkaya, M.H.J Bollen, P.A. Crossley, "Characterization of Voltage Sags in Industrial Distribution System", *IEEE transactions on industry applications, volume 34, No. 4*, July/August, PP.682-688, 1999.

[3] Haque, M.H., "Compensation of Distribution Systems Voltage sags by DVR and D-STATCOM", *Power Tech Proceedings*, 2001 IEEE Porto, Volume 1, PP.10-13, September 2001.

[4] Anaya-Lara O, Acha E., "Modeling and Analysis Of Custom Power Systems by PSCAD/EMTDC", *IEEE Transactions on Power Delivery, Volume 17, Issue: 2002*, Pages: 266-272.

[5] Bollen, M.H.J.,"Voltage sags in Three Phase Systems", Power Engineering Review, *IEEE, Volume 21, Issue: 9*, September 2001, PP: 11-15.

[6] M.Madrigal, E.Acha., "Modelling Of Custom Power Equipment Using Harmonics Domain Techniques",*IEEE 2000.* 

[7] R.Meinski, R.Pawelek and I.Wasiak, "Shunt Compensation for Power Quality Improvement Using a STATCOM controller Modelling and Simulation", *IEEE Proce, Volume 151, No. 2*, March 2004.

[8] J.Nastran , R. Cajhen, M. Seliger, and P.Jereb,"Active Power Filters for Nonlinear AC loads, *IEEE Trans.on Power Electronics Volume 9*, *No.1*, PP: 92-96, Jan 2004.

[9] L.A.Moran, J.W. Dixon, and R.Wallace, A Three Phase Active Power Filter with fixed Switching Frequency for Reactive Power and Current Harmonics Compensation, *IEEE Trans. On Industrial Electronics. Volume* 42, PP: 402-8, August 1995.

[10] L.T. Moran, P.D Ziogas, and G.Joos, Analysis and Design of Three Phase Current source solid State Var Compensator, *IEEE Trans, on Industry Applications. Volume* 25, *No.2*, 1989, PP: 356-65.