

# Control Strategy for Three Phase Grid Connected PV Inverters Enabling Current Limitation under Unbalanced Faults

S.Appalaraju, R.Indhu, A.Chandra Babu,

<sup>1</sup> M.Tech, Department of EEE, YITS, Tirupati

<sup>2</sup> Asst.Prof, Department of EEE, YITS, Tirupati

<sup>3</sup> HOD, Department of EEE, YITS, Tirupati

**Abstract**—Power quality and voltage control are among the most important aspects of the grid-connected power converter operation under faults. Non-sinusoidal current is injected during unbalanced voltage sag and active or/and reactive power includes double frequency content. This paper introduces a new Fuzzy Logic Controller based control approach to mitigate the double grid frequency oscillations in the active power and dc-link voltage of the two-stage three-phase grid-connected Photovoltaic (PV) inverters during unbalanced faults. With the Fuzzy Controller control method, PV inverter injects sinusoidal currents under unbalanced grid faults. In addition, an efficient and easy-to-implement current limitation method is introduced, which can effectively limit the injected currents to the rated value during faults. In this case, the fault-ride-through operation is ensured and it will not trigger the over current protection. A Non-MPPT operation mode is proposed for the dc-dc converter. The mode is enabled under severe faults, when the converter cannot handle the maximum PV power. Finally simulated validation is provided by implementing method at Matlab/Simulink environment and analyses the performance of the complete system with including PV inverter.

**Index Terms**—Active power oscillations; Current limitation; dc-link voltage oscillations; Low-Voltage Ride- Through (LVRT); Photovoltaic (PV) systems.

## I. INTRODUCTION

With the fast increase of grid-connected Photovoltaic (PV) generation, PV systems should contribute to the grid stability by providing ancillary services, beyond the basic power delivery [1-6]. The new grid requirements demand grid-connected PV systems, single- or three-phase, to have the capability to operate in power factors other than unity [7-9]. Also, based on the recently revised grid codes, PV inverters are preferred to stay connected during grid voltage faults [10-13]. When fault happens, the converter has to detect the incident and react quickly to the disturbance to mitigate the adverse effects on the inverter and the equipment connected to the grid, and also the upstream system [14-16]. Indeed, the revised grid codes require PV systems to inject a certain amount of reactive power in case of the low voltage fault, as shown in Fig. 1 [1, 4, 11, 12, 17-19]. This capability is called Low-Voltage Ride-Through (LVRT). A technical report is presented in [19], which requires the PV plants to sustain the grid fault, inject reactive power, and if possible, inject PV power to the grid. As can be seen, usually, for voltage sag depths under 0.5 p.u., the converter is not exploiting the full capacity to inject reactive power. Therefore, the remaining capacity can be utilized for generation of the active power, delivered by the PV array.




Fig. 1. The grid standard of each country, showing the reactive power should be injected to the grid during the faults, regarding the voltage sag depth.

Fundamentally, the LVRT control strategies for grid-connected PV systems under abnormal conditions should (1) quickly detect voltage faults; (2) calculate active and reactive current references in the Positive Sequence

(PS) and Negative Sequence (NS); (3) prevent overcurrent failure (limit current); (4) control the dc-link voltage; and (5) control the dc-dc converter (in two-stage systems). Although the first three issues have been considered in earlier studies, the latter issues for two-stage PV systems remain untreated in details.

Once faults are detected, the current reference generations should be prioritized in the LVRT operation, as it also contributes to the current limitation. Different methods for current reference generation during grid faults have been presented in literature. In [20], the LVRT capability of the single-phase PV inverters is thoroughly discussed. In [21], a review on current reference generation of three-phase PV inverters during grid faults is performed. A few methods such as [22] have discussed the operation of a Pulse Width Modulated (PWM) grid-connected rectifier under grid faults. However, the LVRT strategy in grid-connected PV inverters is challenging, since the dynamics of the PV panels, dc power processing stage, and the capacitive dc-link can affect the operation of the entire system. In [16, 23], an Instantaneous Active Reactive Control (IARC) was proposed, which leads to non-sinusoidal output currents under unbalanced faults. A current reference generation method dealing with both PS and NS aiming at reducing the NS of the grid voltage has been proposed in [24]. However, the active and reactive power waveforms include oscillatory components under unbalanced grid faults. In [25], the LVRT strategy controls both NS and PS to eliminate the active power oscillations under grid faults. In [26], a transformer less three-level PV inverter is introduced and the effects of the unbalanced faults on the neutral point in this inverter are analyzed for LVRT operation. The focus of [26] is on proposing new control strategies to further balance the voltage fluctuations on the neutral point under unbalanced faults. [27] Has proposed a LVRT control strategy in the d-reference frame for the grid-connected converters without considering the characteristics of a renewable energy source, either PV or wind. In [28], a three-phase system has been investigated, which offers six current control freedoms with a zero-sequence current path to mitigate both active and reactive power oscillations and also inject sinusoidal currents. However, in [28], a constant dc source has been used; the negative effects of the unbalanced faults on the capacitive dc-link have not been explored. Also, in [29], the dc-link voltage is assumed to be constant. This assumption is not proper in case of an unbalanced fault as total power would not be zero and ripple would be induced to dc link voltage. Although in [30] a PV source is modeled at the input side, the performance of the Fuzzy controller method is only

discussed through simulations. The LVRT operation of current source grid-connected PV inverters is discussed in [31]. [32] has proposed a flexible control strategy for operation of the three-phase PV inverters under unbalanced faults; however, has not discussed control of the renewable energy source. The Fuzzy controller method in [33] has improved the Dual Vector Current Control (DVCC) method to control the high peak currents and minimize the power ripple. In [34], a control strategy is proposed that balances the PS and NS components utilizing the power capacity of the inverter. However, the injected active and reactive power components still contain oscillatory harmonics. In summary on existing LVRT control challenges, in three-wire three-phase systems, in order to inject sinusoidal currents under unbalanced faults, either active or reactive power or both of them will oscillate with twice the grid fundamental frequency. To further highlight, if neither active nor reactive power oscillates, the injected currents are non-sinusoidal. The aforementioned active power oscillation can have negative impacts on reliable operation of the grid-connected PV converters. In two-stage PV converters, where a dc-dc converter operates as Maximum Power Point Tracking (MPPT), it is common that a PI controller determines the active power reference. Thus, in case that the injected active power starts fluctuating, the PI controller cannot follow the sinusoidal variations in the injected power. This is because the PV power injected to the dc-link is constant. As a result, the dc-link voltage will fluctuate with the same frequency of the injected active power. Notably, due to high failure rates of the electrolytic capacitors of the two-stage PV converters [35], the system reliability is challenged. This is worsening by dc-link voltage ripples. In this paper, dc link ripples during unbalanced faults are reduced with proper control of dc-dc converter. Among the major contributions of the paper is to investigate the effects of the PV arrays on the entire system and propose a control strategy for the PV side under unbalanced grid faults in contrast to [10, 27, 29, 33, 34, 36]; in these works, the current reference generation and grid side control have been discussed. Therefore, the operation of a two-stage grid-connected PV converter under LVRT conditions can be rarely found in the literature. Whereas, in this paper, the operation of the PV arrays, dc-dc converter, and dc-link voltage is carefully evaluated through simulations and experiments under unbalanced grid voltage sags.

In light of the above, this paper proposes (1) a new general and flexible current reference generation method that injects sinusoidal currents even under unbalanced grid faults; (2) a control method that eliminates

double grid frequency oscillations from the injected active power and the dc-link voltage under unbalanced voltage sag faults, improving the long-term reliability of the PV converter; (3) a Non-MPPT operation mode for the dc-dc converter, which is enabled under severe faults, when the converter cannot handle the maximum PV power; (4) an effective current limiting method that can restrict the injected currents to the rated value. In order to realize the aforementioned advantages, the injected reactive power is allowed to oscillate with twice the grid fundamental frequency.

The paper is structured as follows: In Section II, the steady-state operation of a two-stage grid-connected PV system is presented. Section III presents the Fuzzy LVRT strategy. Finally, the Fuzzy Controller algorithm is verified by simulations and also the experiments. Concluding remarks are provided at the end to summarize the advantages of the proposal.

## II. SYSTEM OPERATION

This section is to analyze the inverter operation under normal and abnormal conditions for a three-wire three-phase PV system. The two-stage three-phase system is shown in Fig. 2, which includes a boost converter and a full-bridge inverter interconnected through the dc-link capacitor.

The formulation is performed in the Stationary Reference Frame (SRF). The conversion from the three-phase system into the SRF is as

$$v_{\alpha\beta} = \begin{bmatrix} v_{\alpha} \\ v_{\beta} \end{bmatrix} = \frac{2}{\sqrt{3}} \begin{bmatrix} 1 & -1/2 & -1/2 \\ 0 & \sqrt{3}/2 & -\sqrt{3}/2 \end{bmatrix} \begin{bmatrix} v_a \\ v_b \\ v_c \end{bmatrix} \quad (1)$$

Where  $v_{\alpha}$ ,  $v_{\beta}$  are the voltages in the SRF and  $v_a$ ,  $v_b$ ,  $v_c$  are the grid voltages in the natural reference frame. Since the system is three-wire, the phase currents will not contain zero sequences. Thus, the voltages and currents are obtained as:

$$v_a = V^+ \cos(\omega t + \varphi^+) + V^- \cos(\omega t + \varphi^-) \quad (2)$$

$$v_b = V^+ \cos\left(\omega t - \frac{2\pi}{3} + \varphi^+\right) + V^- \cos\left(\omega t + \frac{2\pi}{3} + \varphi^-\right) \quad (3)$$

$$v_c = V^+ \cos\left(\omega t + \frac{2\pi}{3} + \varphi^+\right) + V^- \cos\left(\omega t - \frac{2\pi}{3} + \varphi^-\right) \quad (4)$$

$$i_a = I^+ \sin(\omega t + \delta^+) + I^- \sin(\omega t + \delta^-) \quad (5)$$

$$i_b = I^+ \sin\left(\omega t - \frac{2\pi}{3} + \delta^+\right) + I^- \sin\left(\omega t + \frac{2\pi}{3} + \delta^-\right) \quad (6)$$

$$i_c = I^+ \sin\left(\omega t + \frac{2\pi}{3} + \delta^+\right) + I^- \sin\left(\omega t - \frac{2\pi}{3} + \delta^-\right) \quad (7)$$

In which,  $V^+$ ,  $V^-$ ,  $I^+$ , and  $I^-$  are the amplitudes of the positive and negative sequences of the grid voltage and

current,  $\varphi^+$ ,  $\varphi^-$ ,  $\delta^+$ , and  $\delta^-$  are the phase angles of the grid voltage and current. The apparent power  $S$  is written as

$$S = v \cdot i^* = P + jQ \quad (8)$$

Where  $v$  and  $i$  are the voltage and current vectors in the SRF, and  $P$ ,  $Q$  are the active and reactive power, respectively. Since under normal conditions the grid voltages and loads are balanced, there will not be any oscillatory components in the active and reactive components of the power also the injected current is completely sinusoidal. However, under unbalanced conditions, the NS components will appear in both current and voltage vectors. Thus, the apparent power is re-written as

$$S = v_{\alpha\beta} \cdot i_{\alpha\beta}^* = (v_{\alpha\beta}^+ + v_{\alpha\beta}^-) \cdot (i_{\alpha\beta}^+ + i_{\alpha\beta}^-)^* \quad (9)$$

$$= v_{\alpha\beta}^+ \cdot i_{\alpha\beta}^{+*} + v_{\alpha\beta}^- \cdot i_{\alpha\beta}^{-*} + v_{\alpha\beta}^- \cdot i_{\alpha\beta}^{+*} + v_{\alpha\beta}^+ \cdot i_{\alpha\beta}^{-*}$$

In which  $v_{\alpha\beta}^+$  and  $v_{\alpha\beta}^-$  are derived from:

$$v_{\alpha\beta}^+ = \frac{1}{2} \begin{bmatrix} 1 & -q \\ q & 1 \end{bmatrix} v_{\alpha\beta} \quad \text{and} \quad v_{\alpha\beta}^- = \frac{1}{2} \begin{bmatrix} 1 & q \\ -q & 1 \end{bmatrix} v_{\alpha\beta} \quad (10)$$

Where  $q^{j\pi/2}$  is a 90°-lagging phase-shifting operator applied to the time domain. Similarly,  $i_{\alpha\beta}^+$  and  $i_{\alpha\beta}^-$  are achieved following (10). In (9), there are four terms in the apparent power formulation. In (12) to (19), these terms are written as active and reactive components  $P_n$  and  $Q_n$ , where  $n$  varies from 1 to 4.

Multiplying two terms with the same sequences will lead to a constant term in the active and reactive power, like in (12), (13), (18), and (19). In contrast, the oscillating parts of the active and reactive power are caused by the multiplication of two terms with inverse sequences, like in (14)-(17). Therefore, the constant and oscillating parts of the total active and reactive power are written as:

$$v_{\alpha\beta}^+ \cdot i_{\alpha\beta}^{+*} = (v_{\alpha}^+ + jv_{\beta}^+) \cdot (i_{\alpha}^+ + ji_{\beta}^+)^* \quad (11)$$

$$= v_{\alpha}^+ i_{\alpha}^{+*} + v_{\beta}^+ i_{\beta}^{+*} + j(v_{\beta}^+ i_{\alpha}^{+*} - v_{\alpha}^+ i_{\beta}^{+*})$$

$$P_1 = v_{\alpha}^+ i_{\alpha}^{+*} + v_{\beta}^+ i_{\beta}^{+*} \quad (12)$$

$$Q_1 = v_{\beta}^+ i_{\alpha}^{+*} - v_{\alpha}^+ i_{\beta}^{+*} \quad (13)$$

$$P_2 = v_{\alpha}^+ i_{\alpha}^{-*} + v_{\beta}^+ i_{\beta}^{-*} \quad (14)$$

$$Q_2 = v_{\beta}^+ i_{\alpha}^{-*} - v_{\alpha}^+ i_{\beta}^{-*} \quad (15)$$

$$P_3 = v_{\alpha}^+ i_{\alpha}^{+*} + v_{\beta}^+ i_{\beta}^{+*} \quad (16)$$

$$Q_3 = v_{\beta}^+ i_{\alpha}^{+*} - v_{\alpha}^+ i_{\beta}^{+*} \quad (17)$$

$$P_4 = v_{\alpha}^+ i_{\alpha}^{-*} + v_{\beta}^+ i_{\beta}^{-*} \quad (18)$$

$$Q_4 = v_{\beta}^+ i_{\alpha}^{-*} - v_{\alpha}^+ i_{\beta}^{-*} \quad (19)$$

$$P = P_0 + \tilde{P} \quad (20)$$

$$P_0 = P_1 + P_4 = v_{\alpha}^+ i_{\alpha}^{+*} + v_{\beta}^+ i_{\beta}^{+*} + v_{\alpha}^+ i_{\alpha}^{-*} + v_{\beta}^+ i_{\beta}^{-*} \quad (21)$$

$$\tilde{P} = P_2 + P_3 = v_{\alpha}^+ i_{\alpha}^{-*} + v_{\beta}^+ i_{\beta}^{-*} + v_{\alpha}^+ i_{\alpha}^{+*} + v_{\beta}^+ i_{\beta}^{+*} \quad (22)$$

$$Q = Q_0 + \tilde{Q} \quad (23)$$

$$Q_0 = Q_1 + Q_4 = v_{\beta}^+ i_{\alpha}^{+*} - v_{\alpha}^+ i_{\beta}^{+*} + v_{\beta}^+ i_{\alpha}^{-*} - v_{\alpha}^+ i_{\beta}^{-*} \quad (24)$$

$$\tilde{Q} = Q_2 + Q_3 = v_{\beta}^+ i_{\alpha}^{-*} - v_{\alpha}^+ i_{\beta}^{-*} + v_{\beta}^+ i_{\alpha}^{+*} - v_{\alpha}^+ i_{\beta}^{+*} \quad (25)$$

Where P and Q are the total active and reactive power, P<sub>0</sub>, Q<sub>0</sub>,

$$\begin{bmatrix} v_{\alpha\perp} \\ v_{\beta\perp} \end{bmatrix} = \begin{bmatrix} 0 & -1 \\ 1 & 0 \end{bmatrix} \begin{bmatrix} v_{\alpha} \\ v_{\beta} \end{bmatrix} \quad (33)$$

where  $v_{\alpha\perp}$  and  $v_{\beta\perp}$  are the orthogonal voltages (90°-lead) of the SRF voltage vectors. In the denominator of (29)-(32), there are two terms  $V_p = (\sqrt{v_{\alpha}^2 + v_{\beta}^2})$  and  $V_n = (\sqrt{v_{\alpha}^2 + v_{\beta}^2})$ . Underbalanced or even unbalanced grid faults, these terms are almost constant. Accordingly, summation or subtraction of  $\sqrt{V_p}$  and  $\sqrt{V_n}$  leads to a constant term, as demonstrated in Fig. 3. Therefore, the denominator in these formulations is constant and without oscillation. Notably,  $Q_{ref}$  is the average value of the reactive power required under the fault according to grid codes. Then, the SRF currents are driven from average value of the active and reactive power. These references determine the peak-peak value of the oscillations on the reactive power. The proposed formulation is customized for different objectives through definition of the following key parameters:  $k_{\alpha P}$ ,  $k_{\beta P}$ ,  $k_{\alpha Q}$ , and  $k_{\beta Q}$ . Accordingly, a general formulation is obtained as

$$i_{\alpha P} = \frac{v_{\alpha}^+ - v_{\alpha}^-}{(v_{\alpha}^{+2} + v_{\beta}^{+2}) + k_{\alpha P}(v_{\alpha}^{-2} + v_{\beta}^{-2})} P_{ref} \quad (34)$$

$$i_{\beta P} = \frac{v_{\beta}^+ - v_{\beta}^-}{(v_{\alpha}^{+2} + v_{\beta}^{+2}) + k_{\beta P}(v_{\alpha}^{-2} + v_{\beta}^{-2})} P_{ref} \quad (35)$$

$$i_{\alpha Q} = -\frac{v_{\alpha\perp}^+ + v_{\alpha\perp}^-}{(v_{\alpha\perp}^{+2} + v_{\beta\perp}^{+2}) + k_{\alpha Q}(v_{\alpha\perp}^{-2} + v_{\beta\perp}^{-2})} Q_{ref} \quad (36)$$

$$i_{\beta Q} = -\frac{v_{\beta\perp}^+ + v_{\beta\perp}^-}{(v_{\alpha\perp}^{+2} + v_{\beta\perp}^{+2}) + k_{\beta Q}(v_{\alpha\perp}^{-2} + v_{\beta\perp}^{-2})} Q_{ref} \quad (37)$$

in which,  $i_{\alpha P}$  and  $i_{\beta P}$  are the active currents in the SRF,  $i_{\alpha Q}$  and  $i_{\beta Q}$  are the reactive currents in the SRF,  $k_{\alpha P}$ ,  $k_{\beta P}$ ,  $k_{\alpha Q}$ , and  $k_{\beta Q}$  are the key parameters, which can be either +1 or -1 to adjust the active and reactive current references in the SRF considering grid requirements. Hence, 16 modes for reference generation exist with unique features, including the active power oscillation, reactive power oscillation, and sinusoidal currents. As mentioned previously, the purpose of this paper is to present a current reference generation method to eliminate oscillations from the active power and the dc-link voltage. Simulation case studies show that only in four modes the double grid frequency oscillations can be mitigated in the injected active power, which is summarized in Table I.

TABLE I  
OPERATION MODES WITH NO ACTIVE POWER  
OSCILLATION.

Mode	$k_{\alpha P}$	$k_{\beta P}$	$k_{\alpha Q}$	$k_{\beta Q}$
Mode 1	+1	+1	+1	+1
Mode 2	-1	-1	-1	-1
Mode 3	+1	+1	-1	-1
Mode 4	-1	-1	+1	+1

In order to exploit the full capacity of the converter, the denominator in (34)-(37) has to meet the lowest value. Thus, the key parameters are considered as listed in Mode 2 in Table I. In this case, the dc-link voltage should remain constant even if an unbalanced grid fault happens. However, it should be noted that due to the small resistances of the inductive filter, these oscillations cannot be completely eliminated from the dc link voltage [29]. The reason is that the oscillatory components consumed by the filter's resistance, are provided by the converter.




Fig. 3. Behavior of the defined parameters under the faults:

(a)  $\frac{\sqrt{V_p} - \sqrt{V_n}}{V_b}$  and (b) NNP – New Nominal Power.

B. Current Limitation Method

In order to prevent the overcurrent failure, a new efficient current limiting method is proposed in the following. The rated power of the converter must be updated once a voltage sag is detected; it is called New Nominal Power (NNP). Normally, under voltage sag faults, the NNP value is less than the nominal power of the converter, which depends on the voltage sag depth. Therefore, the NNP is achieved as

$$NNP = \frac{\sqrt{V_p} - \sqrt{V_n}}{V_{base}} S \tag{38}$$

Where  $S$  is the apparent power or the nominal power of the power converter,  $V_{base}$  is the base voltage, which is equal to the Root-Mean-Square (RMS) value of the line-line grid voltage. In order to verify the effectiveness of this method, a simulation is performed to show that by decreasing the phase voltages, the NNP decreases, which is demanded to restrict the injected currents. At first, three-phase voltages are balanced. Then, at  $t = 0.1$  s, the phase-b voltage falls to 0.7 p.u., while other phase voltages remain the same. The voltage sag orders are shown in Fig. 3. It is clearly demonstrated that the decrease in the phase voltages will result in the reduction in the NNP.

On the other hand, according to the voltage sag depth, the reactive power can be calculated as below [37].

$$\begin{cases} Q = 0 & \text{if } V_{pu} > 0.9 \\ Q = S \times 1.5 \times (0.9 - V_{pu}) & \text{if } 0.2 < V_{pu} < 0.9 \\ Q = 1.05 \times S & \text{if } V_{pu} < 0.2 \end{cases} \tag{39}$$

with  $V_{pu}$  being calculated as

$$V_{pu} = \frac{\sqrt{v_a^2 + v_b^2}}{V_b} \tag{40}$$

Given the NNP and reactive power of  $Q$ , the maximum allowed active power ( $P_{max}$ ) for the inverter to inject to the grid while avoiding overcurrent can be achieved as:

$$P_{max} = \sqrt{NNP^2 - Q^2} \tag{41}$$

For operation of the converter under very deep voltage sags, NNP will have a low value, since  $\sqrt{V_p} - \sqrt{V_n}$  becomes small. Therefore, under a deep voltage sag, the condition is:

$$\text{if } (Q > NNP) \rightarrow Q = NNP, \text{ and } P_{max} = 0 \tag{42}$$

If the reactive power reference is higher than the NNP, the converter cannot inject that much reactive power to the grid. Hence, it should pick the NNP value for the reactive power reference and shed the dc power consumed from the PV arrays.




Fig. 4. P-V characteristics of the PV array. The dc-dc converter switches from MPPT to the Non-MPPT operation mode.

In summary, once voltage sag is detected, the NNP and  $Q$  values are calculated according to (38) and (39). Then, the maximum allowed active power ( $P_{max}$ ) preventing an overcurrent, is determined by (41). During the voltage sag faults,  $P_{max}$  is continuously compared with the active power reference ( $P^*$ ) provided by the dc-link controller. If  $P_{max} > P^*$  the exact amount of active power the converter has been injected previously can be still delivered. On the other hand, if  $P_{max} < P^*$  the inverter cannot inject the active power reference ( $P^*$ ) provided by the dc-link controller. In this case, in order to keep the dc-link voltage constant, the operating point of the PV arrays should move in a way to extract  $P_{max}$  from the PV array. This operation mode is called Non-MPPT mode, which would start in case a voltage sag occurs and  $P_{max} < P^*$ . Fig. 4 shows how the dc-dc converter is controlled in the Non-MPPT mode. The right side of the P-V characteristic is chosen for the Non-MPPT mode, since the ramp is higher; in this case, the operating point can move faster than the

left side. In order to move to the right side, the duty cycle is reduced regarding (43).

$$V_{PV} = (1 - D)V_{dc} \tag{43}$$

Where  $V_{dc}$  and  $V_{PV}$  are the dc-link voltage and PV voltage, respectively. Once the fault occurs and the Non-MPPT operation is activated, an approximate value for the duty cycle is calculated as

$$D_c = \frac{P_{max}}{P_{MPP}} D_{MPP} \tag{44}$$

In which  $D_c$  is the approximate value of the duty cycle for the new operating point,  $D_{MPP}$  and  $P_{MPP}$  are the duty cycle and PV power at the MPP. In Fig. 4, the left big red arrow clarifies shifting the operating point to the new position corresponded to  $\text{Q}$ . The next smaller arrows show the operation of a PI controller adopted to tune the duty cycle of the dc-dc converter.

C. The Control Block Diagram

Fig. 5 represents the proposed Fuzzy control block diagram. The control structure consists of two parts, which can operate independently owing to the capacitive dc-link decoupling the two stages, dc-dc converter and inverter. A PI controller is adopted as a dc voltage regulator. The output of the PI controller determines the active power reference to stabilize the dc link voltage. The current controller block benefits from two Proportional-Resonant (PR) controllers that separately control the injected currents.




Fig. 5. Proposed Fuzzy based control block diagram of the tested.

The dc-dc converter operates as the MPPT, in which the hillclimbing method is adopted. The dc-dc converter should switch to the Non-MPPT mode in case that a grid fault occurs and inverter cannot inject the maximum PV power. Fig. 6 further clarifies the control system. If  $V_{pu}$  falls below 0.9 per-unit, the voltage sag detection block will generate a fault signal activating the NNP, Q, and  $P_{max}$  calculator block. Then, per comparison between  $P_{max}$  and  $P^*$  a comparator signal will be generated. Fig. 7 demonstrates the control of the dc-dc converter. Black dashed-line presents the Non-MPPT control algorithm, which is activated once the Enable Signal is equal to 1.  $D_c$  is the value calculated in previous section. There is an AND block, in which, if the comparator signal and fault signal are equal to 1, the dc-dc converter switches to the Non-MPPT mode. The PI controller tunes the new duty cycle for the Non-MPPT operation. Table II summarizes the PV converter operation under different grid conditions. MPPT may continue working under abnormal operation when the fault exists in the grid and  $P_{max} < P^*$ . It means that the inverter has the capacity to inject maximum power of the PV array as well as the required reactive power. In this case, the fault signal is 1, while the comparator signal remains zero.




Fig. 6. Flowchart of the proposed control algorithm.




Fig. 7. Block diagram of the dc-dc converter control (MPPT vs. Non-MPPT operation).

TABLE II


PV CONVERTER OPERATION UNDER DIFFERENT GRID CONDITIONS

Grid Condition	LVRT	Dc-dc Converter operation
$V_{pu} > 0.9$	Disabled	MPPT
$V_{pu} < 0.9$	$P_{max} > P'$	Enabled MPPT
	$P_{max} < P'$	Enabled Non-MPPT


### III. SIMULATION RESULTS

A simulation testbed is developed in MATLAB/SIMULINK to verify the proposed fuzzy strategy. Table III shows the power converter parameters. The dc-link voltage is assumed to be  $1.3\sqrt{2}V_{L-L,rms}$ , which is equal to 696 V. A case scenario is defined for verification of the fuzzy controller method, in which  $V_b$  and  $V_c$  fall to 0.45 per-unit at  $t = 0.2$  s. Fig. 8(a) shows the three-phase grid voltages. Once the fault occurs,  $V_{pu}$  falls to 0.63 per unit, LVRT operation is enabled. Fig. 8(b) shows the injected currents at the moment of the fault, which are properly controlled by the control strategy. Since the voltage sag is unbalanced, the currents in phase-b and phase-c are increased, however still restricted to 3.04 A, while phase-a decreases. However, the injected currents are purely sinusoidal. The active power is reduced; accordingly, the power extracted from the PV array is reduced by switching from the MPPT to Non-MPPT mode as shown in Fig. 8(c) and (d), respectively. Fig. 9(a) and (b) depict the injected active and reactive power, respectively, under the grid fault. Once an unbalanced voltage sag is detected, the active power is quickly reduced to 315 W ( $P_{Max}$ ) to prevent overcurrent failure. Although the fault is unbalanced, the active power is almost free of double frequency oscillations. Noticeably in Fig. 9(b), the injected reactive power increases to 925 VAR once the fault signal is equal to 1 and oscillates with the grid's double frequency,

which is intended in the fuzzy method. As Fig. 9(c) illustrates, at the instant of the fault, the dc-link voltage is decreased, but after a short time, the dc-link controller reduces the active power reference, which is shown in Fig. 9(d). Fig. 9(c) shows that the dc-link voltage is properly stabilized and recovered to 696 V. Small peak-peak oscillations can be observed at the dc-link due to the double-frequency component of the power that is consumed by the filter.



(a)



(b)

Fig. 8. Simulation results of the PV system: (a) SIMULINK Model for the proposed System (b) three-phase grid voltages, three-phase currents, PV voltage, and PV power, at the moment of the unbalanced fault.



(a)




Fig. 9. Simulation results of the PV system: (a) injected active power, (b) injected reactive power, (c) dc-link voltage

## VI. CONCLUSION

This paper has proposed a fuzzy based control scheme for the three-wirethree-phase two-stage PV converter to improve the power quality under abnormal conditions. Among the major contributions of the fuzzy controller method is the mitigation of the double grid frequency oscillations in the dc-link voltage and the active power under unbalanced faults. Using the proposed current reference generation, the injected currents are sinusoidal with the THD value of lower than 5% in the experiments. More importantly, the control structure benefits from two operation modes, MPPT and Non-MPPT, both of which can operate under abnormal conditions. One of the main contributions of the paper is that a Non-MPPT operation mode for the dc-dc converter is introduced and experimentally implemented. This operation mode is comprehensively investigated in this paper considering PV arrays at the input side. This feature contributes to the current limitation method that restricts the injected currents to the rated value. In contrast to the earlier current limiting methods, the Fuzzy logic controller method benefits from a mathematical model that can be easily implemented in the embedded controller.

## REFERENCES

- [1] R. Meyer, A. Zlotnik, and A. Mertens, "Fault Ride-Through Control of Medium-Voltage Converters With LCL Filter in Distributed Generation Systems," *IEEE Trans. Ind. Appl.*, vol. 50, no. 5, pp. 3448-3456, 2014.
- [2] J. Hu, Y. He, L. Xu, and B. W. Williams, "Improved control of DFIG systems during network unbalance using PI-R current regulators," *IEEE Trans. Ind. Electron.*, vol. 56, no. 2, pp. 439-451, 2009.
- [3] J. Miret, M. Castilla, A. Camacho, L. G. d. Vicu, and J. Matas, "Control Scheme for Photovoltaic Three-Phase Inverters to Minimize Peak Currents During Unbalanced Grid-Voltage Sags," *IEEE Trans. Power Electron.*, vol. 27, no. 10, pp. 4262-4271, 2012.
- [4] R. Rahimi, E. Afshari, B. Farhangi, and S. Farhangi, "Optimal placement of additional switch in the photovoltaic single-phase grid-connected transformerless full bridge inverter for reducing common mode leakage current," in *2015 IEEE Conference on Energy Conversion (CENCON)*, 2015, pp. 408-412.
- [5] R. Rahimi, B. Farhangi, and S. Farhangi, "New topology to reduce leakage current in three-phase transformerless grid-connected photovoltaic inverters," in *2016 7th Power Electronics and Drive Systems Technologies Conference (PEDSTC)*, 2016, pp. 421-426.
- [6] E. Afshari, R. Rahimi, B. Farhangi, and S. Farhangi, "Analysis and modification of the single phase transformerless FB-DCB inverter modulation for injecting reactive power," in *2015 IEEE Conference on Energy Conversion (CENCON)*, 2015, pp. 413-418.
- [7] G. R. Moradi, E. Afshari, R. Rahimi, B. Farhangi, and S. Farhangi, "Improvement of the modulation method for single-phase transformerless photovoltaic conergy inverter for reactive power injection capability," in *2016 24th Iranian Conference on Electrical Engineering (ICEE)*, 2016, pp. 1312-1317.
- [8] C. Schauder, "Impact of FERC 661-A and IEEE 1547 on photovoltaic inverter design," in *Power and Energy Society General Meeting, 2011 IEEE*, 2011, pp. 1-6.
- [9] J. L. Sosa, M. Castilla, J. Miret, J. Matas, and Y. A. Al-Turki, "Control Strategy to Maximize the Power Capability of PV Three-Phase Inverters During Voltage Sags," *IEEE Trans. Power Electron.*, vol. 31, no. 4, pp. 3314-3323, 2016.
- [10] F. Iov, A. D. Hansen, P. E. Sørensen, and N. A. Cutululis, "Mapping of grid faults and grid codes," *Risø National Laboratory 8755036228*, 2007.
- [11] Y. Yang, A. Sangwongwanich, H. Liu, and F. Blaabjerg, "Low voltage ride-through of two-stage grid-connected photovoltaic systems through the inherent linear power-voltage characteristic," in *Applied Power Electronics Conference and Exposition (APEC), 2017 IEEE*, 2017, pp. 3582-3588.
- [12] J. P. MitraMirhosseini, Vassilios G. Agelidis, "Single- and Two-Stage Inverter-Based Grid-Connected Photovoltaic Power Plants With Ride-



- Through Capability Under Grid Faults," IEEE Trans. Sustain. Energy, vol. 6, no. 3, pp. 1150-1159, 2015.
- [13] Y. Bae, T. K. Vu, and R. Y. Kim, "Implemental Control Strategy for Grid Stabilization of Grid-Connected PV System Based on German Grid Code in Symmetrical Low-to-Medium Voltage Network," IEEE Trans. Energy Convers., vol. 28, no. 3, pp. 619-631, 2013.
- [14] P. Rodriguez, A. V. Timbus, R. Teodorescu, M. Liserre, and F. Blaabjerg, "Flexible Active Power Control of Distributed Power Generation Systems During Grid Faults," IEEE Trans. Ind. Electron., vol. 54, no. 5, pp. 2583-2592, 2007.
- [15] G. Ding, F. Gao, H. Tian, C. Ma, M. Chen, G. He, et al., "Adaptive DC Link Voltage Control of Two-Stage Photovoltaic Inverter During Low Voltage Ride-Through Operation," IEEE Trans. Power Electron., vol. 31, no. 6, pp. 4182-4194, 2016.
- [16] W. L. XiaoqiangGuo, Xue Zhang, Xiaofeng Sun, Zhigang Lu, and Josep M. Guerrero, "Flexible Control Strategy for Grid-Connected Inverter Under Unbalanced Grid Faults Without PLL," IEEE Trans. Power Electron., vol. 30, pp. 1773-1778, 2015.
- [17] D. Energinet, "Technical regulation 3.2. 2 for PV power plants with a power output above 11 kW," Tech. Rep., 2015.
- [18] Y. Yang, F. Blaabjerg, and H. Wang, "Low-Voltage Ride-Through of Single-Phase Transformerless Photovoltaic Inverters," IEEE Trans. Ind. Appl., vol. 50, no. 3, pp. 1942-1952, 2014.
- [19] D. Energinet, "Technical regulation 3.2. 2 for PV power plants with a power output above 11 kW," Tech. Rep., 2015.
- [20] Y. Yang, F. Blaabjerg, and H. Wang, "Low-Voltage Ride-Through of Single-Phase Transformerless Photovoltaic Inverters," IEEE Trans. Ind. Appl., vol. 50, no. 3, pp. 1942-1952, 2014.
- [21] E. Afshari, G. R. Moradi, Y. Yang, B. Farhangi, and S. Farhangi, "A Review on Current Reference Calculation of Three-Phase Grid- Connected PV Converters under Grid Faults," in IEEE Power and Energy Conference at Illinois (PECI), Illinois, USA, 2017.
- [22] P. Rioual, H. Pouliquen, and J.-P. Louis, "Regulation of a PWM rectifier in the unbalanced network state using a generalized model," IEEE Trans. Power Electron., vol. 11, no. 3, pp. 495-502, 1996.
- [23] R. Teodorescu, M. Liserre, and P. Rodriguez, Grid converters for photovoltaic and wind power systems vol. 29: John Wiley & Sons, 2011.
- [24] C. T. Lee, C. W. Hsu, and P. T. Cheng, "A Low-Voltage Ride-Through Technique for Grid-Connected Converters of Distributed Energy Resources," IEEE Trans. Ind. Appl., vol. 47, no. 4, pp. 1821-1832, 2011.
- [25] Z. Shao, X. Zhang, F. Wang, R. Cao, and H. Ni, "Analysis and Control of Neutral-Point Voltage for Transformerless Three-Level PV Inverter in LVRT Operation," IEEE Trans. Power Electron., vol. 32, no. 3, pp. 2347-2359, 2017.
- [26] S. Alepuz, S. Busquets-Monge, J. Bordonau, J. A. Martínez-Velasco, C. A. Silva, J. Pontt, et al., "Control strategies based on symmetrical components for grid-connected converters under voltage dips," IEEE Trans. Ind. Electron., vol. 56, no. 6, pp. 2162-2173, 2009.
- [27] K. Ma, W. Chen, M. Liserre, and F. Blaabjerg, "Power controllability of a three-phase converter with an unbalanced AC source," IEEE Trans. Power Electron., vol. 30, no. 3, pp. 1591-1604, 2015.
- [28] R. Cárdenas, M. Díaz, F. Rojas, J. Clare, and P. Wheeler, "Resonant control system for low-voltage ride-through in wind energy conversion systems," IET Power Electronics, vol. 9, no. 6, pp. 1297-1305, 2016.
- [29] E. Afshari, B. Farhangi, Y. Yang, and S. Farhangi, "A Low-Voltage Ride- Through Control Strategy for Three-Phase Grid-Connected PV Systems " in IEEE Power and Energy Conference at Illinois (PECI), Illinois, USA, 2017.
- S.Appalaraju** pursuing M.Tech degree in the stream of Power Systems from YOGANANDHA INST OF TECHNOLOGY AND SCIENCE. He was completed his B.Tech from Srikalahasteeswara Institute of Technology in Srikalahasti.
- R.Indhu** has received his B.Tech degree in Electrical & Electronics Engineering from St.Peters's College of Engineering and M.Tech degree in power systems from St.Joseph's College of Engineering.
- A.Chandra Babu** presently working as an Associate Professor & HOD in the department of EEE in YITS, Tirupati, A.P. His research areas are power system operation and power system Optimizations